

論文 / 著書情報
Article / Book Information

題目(和文)	メルトリファイニングプロセスを用いたCANDLE燃焼での燃料被覆交換に関する核的研究
Title(English)	Neutronic Study on Fuel Recladding for CANDLE Burning with Melt and Refining Procedures
著者(和文)	AbdulKarimJuliaBinti
Author(English)	Julia Abdulkarim
出典(和文)	学位:博士(工学), 学位授与機関:東京工業大学, 報告番号:甲第10171号, 授与年月日:2016年3月26日, 学位の種別:課程博士, 審査員:小原 徹,井頭 政之,千葉 敏,高橋 実,相楽 洋
Citation(English)	Degree:Doctor (Engineering), Conferring organization: Tokyo Institute of Technology, Report number:甲第10171号, Conferred date:2016/3/26, Degree Type:Course doctor, Examiner:,,,,
学位種別(和文)	博士論文
Category(English)	Doctoral Thesis
種別(和文)	論文要旨
Type(English)	Summary

(博士課程)
Doctoral Program

論文要旨

THESIS SUMMARY

専攻 :
Department of NUCLEAR ENGINEERING 専攻

学生氏名 : JULIA ABDUL KARIM
Student's Name

申請学位 (専攻分 博士
野) : Doctor of (Engineering)

Academic Degree Requested

指導教員 (主) : TORU OBARA
Academic Advisor(main)

指導教員 (副) : YOSHIHISA MATSUMOTO
Academic Advisor(sub)

要旨 (英文 800 語程度)
Thesis Summary (approx.800 English Words)

The application of melt and refining procedures is found able to solve the metal fuel and its cladding integrity at high burnup condition of CANDLE reactors. The idea of applying the melt and refining procedures to the CANDLE burnup before it reaches the cladding limitation would seem a possible solution for the metal fuel cladding integrity problem at high burnup. However, if melt and refining procedures are applied during operation, the reactor might lose all the nuclides distribution in the fuel pins and CANDLE burning become impossible to achieve. The purpose of this study was to investigate the possibility of applying melt and refining procedures in CANDLE operations, to solve the cladding limitation problem due to radiation displacement damaged at high burnup condition, to estimate the effects of burnup performance improvement on removal of fission products and also to investigate the effects of cooling time during melt and refining procedure. In this study, a large LBE core at 3000MWth at 65% of fuel volume ratio (FVR) with metal fuel and ODS cladding was set as a reference core case. The initial core loading are assembled using 50 load-and-discharge units (LDUs) that are arranged axially in the core. In the calculation, the CANDLE core are divided into 50 zones in axial and 20 zones in radial region. The burnup operation are calculated at 3167 days in 1 fuel movement cycle (FMC). The frequency of applying melt and refining (MR) procedures to the CANDLE core are quantified from the radiation damaged to the fuel cladding during the operation. All of the fuel pins that received $\geq 200\text{dpa}$ shall underwent MR procedures in the appropriate time. In the MR procedures, the fuel element are cut into several melt and refining region (MRR) and refabricated/recladded to reuse in the CANDLE core. Three different melt and refining region (9MRR, 5MRR and 3MRR) are simulated to obtain the appropriate region for the CANDLE burning. The volatile and reactive fission products are released in the MR procedures. The cooling time interval between melt and refining cycle (MRC) are also been investigated. The cooling time of 1, 2, 4 and 8 years are simulated at each MRC to investigate its effects to the CANDLE burning. The SRAC and COREBN code are used to calculate the MR procedures with nuclear data libraries of JENDL3.3.

It became clear that with the application of MR procedures, it is feasible to achieve CANDLE burning if the appropriate number of regions is chosen based on practical core design. The fission products released by the MR procedures has given significant impact to the burnup performance of the CANDLE core. It is found that the effective multiplication factor has increased up to 4% and its burnup increased at $\sim 22\%$. The FVR can be reduced at $\sim 48\%$ with the fission products removal without reducing its burnup performances. This mean, it is also able to improve the engineering design by reducing the fuel volume fraction to the practical value. The effects of cooling time to the excess reactivity varies with the cooling period. At ≤ 4 years of cooling interval, it has gave little effects to the change of effective multiplication factor. The significant cooling effects can be observed if the cooling interval ≥ 8 years. It is found that the effective multiplication factor has reduced significantly due to the accumulation of AM241 in the longer cooling time. It was shown that the cladding limitation can be solved by MR procedures and it can also improve the burnup performance of the reactor.

備考 : 論文要旨は、和文 2000 字と英文 300 語を 1 部ずつ提出するか、もしくは英文 800 語を 1 部提出してください。
Note: Thesis Summary should be submitted in either a copy of 2000 Japanese Characters or 300 Words (English) or 1copy of 800 Words (English).
注意 : 論文要旨は、東工大リサーチリポジトリ (T2R2) にてインターネット公表されますので、公表可能な範囲の内容で作成してください。
Attention: Thesis Summary will be published on Tokyo Tech Research Repository Website (T2R2).