

論文 / 著書情報
Article / Book Information

題目(和文)	
Title(English)	Study on Improvement of Decontamination Factor of Filtered Containment Venting System
著者(和文)	TRANTri Vien
Author(English)	Tri Vien Tran
出典(和文)	学位:博士(工学), 学位授与機関:東京工業大学, 報告番号:甲第11991号, 授与年月日:2021年3月26日, 学位の種別:課程博士, 審査員:木倉 宏成,加藤 之貴,赤塚 洋,相樂 洋,筒井 広明
Citation(English)	Degree:Doctor (Engineering), Conferring organization: Tokyo Institute of Technology, Report number:甲第11991号, Conferred date:2021/3/26, Degree Type:Course doctor, Examiner:,,,,
学位種別(和文)	博士論文
Category(English)	Doctoral Thesis
種別(和文)	論文要旨
Type(English)	Summary

(博士課程)
Doctoral Program

論文要旨

THESIS SUMMARY

系・コース：	Mechanical Engineering	系	申請学位 (専攻分野)：	博士	(Engineering)
Department of, Graduate major in	Nuclear Engineering	コース	Academic Degree Requested	Doctor of	
学生氏名：	Tran Tri Vien		指導教員 (主)：	Hiroshige KIKURA	
Student's Name			Academic Supervisor(main)		
			指導教員 (副)：		
			Academic Supervisor(sub)		

要旨 (英文 800 語程度)

Thesis Summary (approx.800 English Words)

The thesis title is Study on Improvement of Decontamination Factor of Filtered Containment Venting System. The main focus of this dissertation is to investigate the effects of the double-stage venturi scrubber nozzle on the improvement of the decontamination factor of a wet-type scrubber-based Filtered Containment Venting System. The dissertation includes five chapters outlined below:

Chapter 1 - Introduction gives an overview of the development of the filtered containment venting system (FCVS), the importance and status of implementation of FCVS for nuclear reactors. One of the most important lessons learned from the accident of Fukushima Daiichi Nuclear Power Plant is that a system should be required for accident management. A Filtered Containment Venting System (FCVS) is one of such systems that can enhance the capacity to suppress the occurrence of a severe accident due to reduction of steam water, flammable gas, and then pressure in the reactor vessel. To understand the performance of an FCVS, the experiments were conducted on a laboratory scale wet-scrubber FCVS. An advanced venturi scrubber (AVS) nozzle was used to inject gas stream into the system. The nozzle was designed by Prof. Narabayashi as the double-stage venturi nozzle with a baffle plate installed at the exit to change the gas phase flow direction from vertical to lateral. In the previous studies, the AVS nozzle showed its effectiveness to remove the aerosol particles from the venting flow. However, the mechanisms that the AVS nozzle affects the decontamination factor of FCVS has not been investigated deeply. The objective of this dissertation is to study the effects of this venturi scrubber nozzle on the decontamination factor of FCVS and the two-phase flow mechanism.

In Chapter 2 - Effects of Double Stage Venturi Scrubber Nozzle on Liquid Injected Flow, the experimental apparatus of FCVS and AVS nozzle will be described in detail. As using AVS nozzle, a high velocity of the gas stream was presented in the throat, the water is atomized and formed small droplets in the throat through a small hole due to the difference of the hydrostatic pressure at the outside and static pressure at the inside of the throat. An amount of aerosol carried in the air stream can be removed due to interaction with the water droplets in the nozzle throat and diffuser. Therefore, the efficiency of the venturi scrubber also depends on the atomization liquid flow rate into the nozzle. The atomization water flow rate through narrow gaps on the nozzle throat was measured using a combination method of Ultrasonic Velocity Profiler and Particle Tracking Velocimetry. A comparison for the atomization water flow rate between the using single-stage and double-stage venturi scrubber was performed. It showed that the atomization water flow rate was higher by using the double stage venturi scrubber nozzle. And it is an explanation for the improvement of the FCVS decontamination factor by using a double-stage venturi scrubber which has been measured in the previous research.

In Chapter 3 - Effects of Baffle Plate of Advanced Venturi Scrubber on Decontamination Factor of Filtered Containment Venting System, a comparison of the FCVS aerosol decontamination factor between using two configurations of nozzle: with and without the baffle plate to understand the impact of the baffle plate on the removal efficiency of FCVS. The visualized observation was applied using a high-speed camera and backlight illumination to understand how the baffle plate impacts the flow pattern in the wet scrubber. As the result, the baffle plate contributed to change the moving direction of the gas phase at the exit of the nozzle. In this way, it increased the residence time of air bubbles in the water column and increasing the fluctuation of the gas phase in the pool. The results of measurement of the bubble column height showed that with the baffle plate, the aerated

height of the bubble column was smaller. It contributed to decreasing the entrainment effects. It also allows a higher accumulation of water in the scrubber, and therefore, it increases the decontamination factor and capacity of decay heat removal of FCVS.

Chapter 4 – Interactions in Mixing Flow. In general, the aerosol removal efficiency of the nozzle depends on the relative velocity between the gas and the liquid droplets. In this chapter, the water droplet velocity field inside the nozzle was measured using the Particle Image Velocimetry method using backlight illumination to understand how the baffle plate affects the liquid droplet velocity field. The results showed that the baffle plate decreased the droplet velocity in the nozzle. Thus, it contributed to increasing the decontamination factor. The observation of a high-speed camera also showed that there was a film layer of liquid on the surface of the baffle plate. Therefore, the change in direction of the airflow at the exit of the nozzle under the effect of the baffle plate may increase the centrifugal force which impacts the aerosol particles. Thus, the particles tend to slip out to contact and be absorbed into the liquid layer on the baffle plate surface.

In Chapter 5 – Conclusion, the summary of findings from Chapter 2 to Chapter 4 was described.

備考：論文要旨は、和文 2000 字と英文 300 語を 1 部ずつ提出するか、もしくは英文 800 語を 1 部提出してください。

Note : Thesis Summary should be submitted in either a copy of 2000 Japanese Characters and 300 Words (English) or 1copy of 800 Words (English).

注意：論文要旨は、東工大リサーチリポジトリ(T2R2)にてインターネット公表されますので、公表可能な範囲の内容で作成してください。

Attention: Thesis Summary will be published on Tokyo Tech Research Repository Website (T2R2).